

ICC-ES Evaluation Report**ESR-3685**

Issued September 2014

This report is subject to renewal September 2015.www.icc-es.org | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

DIVISION: 04 00 00—MASONRY**Section: 04 71 00—Manufactured Brick Masonry****Section: 04 73 00—Manufactured Stone Masonry****REPORT HOLDER:****CREATIVE MINES, LLC**
100 HESS DRIVE
MALAD, IDAHO 83252
(800) 453-7040
www.creativemines.us**EVALUATION SUBJECT:****CREATIVE MINES ADHERED MASONRY VENEER****1.0 EVALUATION SCOPE****Compliance with the following codes:**

- 2012 *International Building Code*® (IBC)
- 2012 *International Residential Code*® (IRC)

Properties evaluated:

Veneer strength and durability

2.0 USES

Creative Mines Adhered Masonry Veneer is used as an adhered, nonload-bearing exterior veneer on nonfire-resistance-rated wood-framed or light gage steel stud walls, masonry walls and concrete walls.

3.0 DESCRIPTION

Creative Mines Adhered Masonry Veneer is a precast concrete product made to resemble natural stone or brick in color and texture. The concrete is comprised of cement, aggregate, water, admixtures and coloring. The veneer units are molded and cured at the plant. The veneer units are of various thicknesses from $\frac{5}{8}$ inch to $1\frac{5}{8}$ inches (15.9 to 41 mm). The average saturated weight of the installed veneer units does not exceed 15 pounds per square foot (73.2 kg/m²). Recognized patterns of veneer are listed in Table 1.

4.0 DESIGN AND INSTALLATION**4.1 General:**

Installation of Creative Mines Adhered Masonry Veneer must comply with this report, the manufacturer's published installation instructions, and the applicable code. The manufacturer's published installation instructions must be

available at the jobsite at all times during installation. The veneer may be applied over backings of cement plaster.

4.2 Preparation of Cement Plaster Backing:

Cement plaster backings may be applied over plywood, OSB or gypsum sheathing, supported by wood or steel studs, or over masonry or concrete walls when installed as described in Sections 4.2.1 and 4.2.2, respectively.

4.2.1 Installation over Studs: The cement plaster backing must be installed over a water-resistive barrier complying with IBC Sections 1404.2 and 2510.6 or IRC Sections R703.2 and R703.6.3, as applicable. Also, flashing must be installed as required by IBC Sections 1405.4 and 1405.10.1.2 or IRC Sections R703.8 and R703.12.2, as applicable, and weep screeds must be installed at the bottom of the masonry veneer. The weep screeds must comply with, and be installed in accordance with, IBC Section 1405.10.1.2 or IRC Section R703.12.2, as applicable. In addition, the weep screeds must have holes with a minimum diameter of $\frac{3}{16}$ inch (4.8 mm) spaced at a maximum of 33 inches (838 mm) on center, as required by Section 6.1.6.2 of TMS 402/ACI 530/ASCE5, which is referenced in IBC Section 1405.10. The veneer must be installed with the clearances required by IBC Section 1405.10.1.3 or IRC Section R703.12.1, as applicable.

Studs must be spaced no more than 16 inches (406 mm) on center. Lath must be 2.5 lb/yd² (1.4 kg/m²), self-furred metal lath conforming to ASTM C847. All lath must be installed over the water-resistive barriers by following the lath manufacturer's installation instructions. Lath must be fastened to each of the wall studs as required by ASTM C1063 and IRC Section R703.6.1. Fasteners must be spaced a maximum of 6 inches (153 mm) on center.

For attaching lath to wood studs, fasteners must be corrosion-resistant nails or staples complying with Section 7.10.2.2 of ASTM C1063 (for the IBC) or with IRC Section R703.6.1, as applicable. For attaching lath to steel studs, fasteners must be modified truss head, self-drilling tapping screws having a minimum head diameter of $\frac{7}{16}$ (11.1 mm) inch and sufficient length to protrude a minimum of $\frac{3}{4}$ inch (19 mm) through the stud.

A scratch coat of Type N mortar (cement plaster) complying with ASTM C926 must be applied over the lath to a thickness of $\frac{1}{2}$ inch (13 mm). The scratch coat must be allowed to cure in accordance with IBC Section 2512.6, prior to the application of the veneer units.

4.2.2 Installation over Concrete and Masonry: Lath must be minimum 2.5 lb/yd² (1.4 kg/m²), self-furred metal

lath complying with ASTM C847. The lath must be fastened to the wall in accordance with Section 7.10.5 of ASTM C1063 and Section R7036.1 of the IRC, as applicable. The fasteners must be spaced a maximum of 6 inches (152 mm) on center vertically and 16 inches (406 mm) on center horizontally. The gravity load (shear capacity) and negative wind load (pull-out) capacity of the proprietary fasteners must be justified to the satisfaction of the code official. The scratch coat must be applied as described in Section 4.2.1.

4.3 Application of Veneer Units:

A minimum 1/2-inch-thick (12.7 mm) setting bed of Type N mortar must be applied to the back of the veneer units, and the veneer units must be pressed firmly in place in accordance with the manufacturer’s published installation instructions. Joints between veneer units must be grouted and tooled in accordance with the veneer manufacturer’s published installation instructions.

5.0 CONDITIONS OF USE

The precast stone veneer described in this report complies with, or is a suitable alternative to what is specified in, those codes listed in Section 1.0 of this report, subject to the following conditions:

- 5.1 Installation must comply with this report, the manufacturer’s published installation instructions and the applicable code. In the event of a conflict between the manufacturer’s published installation instructions and this report, this report governs.
- 5.2 Use of the precast stone veneer is limited to installations on walls with cement plaster backings.

5.3 Expansion or control joints, used to limit the effect of differential movement of supports on the veneer system, are to be specified by the architect, designer or veneer manufacturer, in that order. Consideration must also be given to movement caused by temperature change, shrinkage, creep and deflection.

5.4 The supporting wall must be designed to support the installed weight of the veneer system, including veneer, setting bed and cement plaster backing, as applicable. At wall openings the supporting members must be designed to limit deflection to 1/600 of the span of the supporting members.

5.5 Where the seismic provisions of IRC Section R301.2.2 apply, the average weight of the wall supporting the precast stone veneer, including the weight of the veneer system, must be determined. When this weight exceeds the applicable limits of IRC Section R301.2.2.2.1, an engineered design of the wall construction must be performed in accordance with IRC Section R301.1.3.

6.0 EVIDENCE SUBMITTED

Data in accordance with the ICC-ES Acceptance Criteria for Precast Stone Veneer (AC51), dated June 2013.

7.0 IDENTIFICATION

Packaged precast stone veneer units are identified with the manufacturer’s name (Creative Mines, LLC), the pattern name, the manufacturing date and location, and the evaluation report number (ESR-3685).

TABLE 1—RECOGNIZED PATTERNS

PRODUCT	PATTERNS
Crafted Masonry Veneer	River Ledge, Foothill Rubble, Farmhouse Ledge, Orchard Limestone, Peak Ledge, Urban Ledge, Boardform Innerpiece, Slit Modular, Flame Rectangle, Carved Rectangle, Chiseled Rectangle (Light), Plowed Rectangle, Loft Paint-grade Brick, Brewery Paint-grade Brick, Modern Paint-grade Brick, Modern Paint-grade Block

ICC-ES Evaluation Report**ESR-3685 CBC and CRC Supplement***Issued September 2014**This report is subject to renewal September 2015.*www.icc-es.org | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

DIVISION: 04 00 00—MASONRY
Section: 04 71 00—Manufactured Brick Masonry
Section: 04 73 00—Manufactured Stone Masonry

REPORT HOLDER:

CREATIVE MINES, LLC
100 HESS DRIVE
MALAD, IDAHO 83252
(800) 458-7040
www.creativemines.us

EVALUATION SUBJECT:**CREATIVE MINES ADHERED MASONRY VENEER****1.0 REPORT PURPOSE AND SCOPE****Purpose:**

The purpose of this evaluation report supplement is to indicate that Creative Mines adhered masonry veneer, recognized in ICC-ES master evaluation report ESR-3685, has also been evaluated for compliance with the codes and applicable chapters noted below.

Applicable code editions:

- 2013 *California Building Code*® (CBC), Chapters 8, 14 and 21
- 2013 *California Residential Code*® (CRC), Chapters 3 and 7

2.0 CONCLUSIONS**2.1 CBC:**

The Creative Mines adhered masonry veneer, described in Sections 2.0 through 7.0 of the master evaluation report ESR-3685, complies with CBC Sections 803.1.1, 1404.4, and 2101.2.6, provided the design and installation are in accordance with the *International Building Code*® provisions noted in the master report and the additional requirements of CBC Sections 1405.1.1, 1405.3 and 1410, as applicable.

The products recognized in this supplement have not been evaluated under CBC Chapter 7A for use in the exterior design and construction of new buildings located in any Fire Hazard Severity Zone within State Responsibility Areas or any Wildland–Urban Interface Fire Area.

2.2 CRC:

The Creative Mines adhered masonry veneer, described in Sections 2.0 through 7.0 of the master evaluation report ESR-3685, complies with the flame spread and smoke developed requirements of CRC Section R302.9 and with CRC Section R703, provided the design and installation are in accordance with the *International Residential Code*® provisions noted in the master report and the additional requirements of CRC Sections R301.1.3 and R702.7.

The products recognized in this supplement have not been evaluated under CRC Section R327 for use in the exterior design and construction of new buildings located within any Fire Hazard Severity Zone within State Responsibility Areas or any Wildland–Urban Interface Fire Area.

The products recognized in this supplement have not been evaluated for compliance with the *International Wildland–Urban Interface Code*®.

This supplement expires concurrently with the master report issued September 2014.

ICC-ES Evaluation Report**ESR-3685 FBC Supplement***Issued September 2014**This report is subject to renewal September 2015.*www.icc-es.org | (800) 423-6587 | (562) 699-0543*A Subsidiary of the International Code Council®***DIVISION: 04 00 00—MASONRY****Section: 04 71 00—Manufactured Brick Masonry****Section: 04 73 00—Manufactured Stone Masonry****REPORT HOLDER:****CREATIVE MINES, LLC
100 HESS DRIVE
MALAD, IDAHO 83252
(800) 458-7040****EVALUATION SUBJECT:****CREATIVE MINES ADHERED MASONRY VENEER****1.0 REPORT PURPOSE AND SCOPE****Purpose:**

The purpose of this evaluation report supplement is to indicate that Creative Mines Adhered Masonry Veneer, recognized in ICC-ES master evaluation report ESR-3685, has also been evaluated for compliance with the codes noted below.

Applicable code editions:

- 2010 *Florida Building Code—Building*
- 2010 *Florida Building Code—Residential*

2.0 CONCLUSIONS

The Creative Mines Adhered Masonry Veneer, described in Sections 2.0 through 7.0 of the master evaluation report ESR-3685, complies with the 2010 *Florida Building Code—Building* and the 2010 *Florida Building Code—Residential*, provided the design and installation are in accordance with the *International Building Code*® provisions noted in the master report and the veneer has a clearance to the final earth grade on the exterior of the building as required by Section 1403.7 of the 2010 *Florida Building Code—Building* or Section R704 or the 2010 *Florida Building Code—Residential*, as applicable.

Use of the Creative Mines Adhered Masonry Veneer for compliance with the High-Velocity Hurricane Zone provisions of the 2010 *Florida Building Code—Building* and the 2010 *Florida Building Code—Residential* has not been evaluated, and is outside the scope of this evaluation report.

For products falling under Florida Rule 9N-3, verification that the report holder's quality assurance program is audited by a quality assurance entity approved by the Florida Building Commission for the type of inspections being conducted is the responsibility of an approved validation entity (or the code official when the report holder does not possess an approval by the Commission).

This supplement expires concurrently with the master report issued September 2014.